



Klet				
poz.	prostor	površina	obdelava poda	obdelava sten
I	GARAŽA	652,88	estrih	vidi balon
I	MOTORIJ	34,35	estrih	vidi balon
I	UVOZNA KLANČINA	110,35	estrih	vidi balon
I	DVIGALO	2,31		
I	HOVNIK I	27,76	protipalni optek	optek
I	KOLEBARNICA	30,27	Keramika	optek
I	POŽARNO STOPNIŠČE	34,29	glin.	protipalni optek
I	SHRAMBA I	0,02	Keramika	optek
I	SHRAMBA I	88,76	protipalni optek	optek
I	SHRAMBA I	100,82	protipalni optek	optek
II	DVIGALO	2,31		
II	HOVNIK II	29,44	protipalni optek	optek
II	KOLEBARNICA II	29,40	protipalni optek	optek
II	POŽARNO STOPNIŠČE	34,29	glin.	protipalni optek
II	SHRAMBA II	0,02	Keramika	optek
II	SHRAMBA II	81,27	protipalni optek	optek
II	SHRAMBA II	100,82	protipalni optek	optek

SIMBOL	OPIS SVETILKE
A01A	SW/2600lm/2700K, IP65
A01	LED/20W/2600lm/4000K, IP65
A02	LED/40W/5200lm/4000K, IP65
A04	SMART H LED/28W/2278lm/4000K/corridor function, IP65
A05	POINTER LED/9W/1350lm/4000K, IP66
Z01	FORMULA65 LED OPTICDM LED/7,5W/315lm/SE/AT/1h, IP65
Z02	FORMULA65 LED/7,5W/315lm/SE/AT/1h, IP65 + stenski nosilec (19045), h=2,2m
Z03	UP LED OPTICDM LED/7,5W/250lm/SE/AT/1h, IP65
Z04	UP LED OPTICDM LED/7,5W/450lm/SE/AT/1h, IP65
P02	UP LED EXIT OPTICDM LED/7,5W/SA/AT/1h, IP40, L/D
P04	UP LED OPTICDM LED/7,5W/250lm/SE/AT/1h, IP65 + displej ravno, montaža na steno
P05	FORMULA65 LED OPTICDM LED/7,5W/315lm/SE/AT/1h, IP65 + piktogram nalepka ravno
P06	FORMULA65 LED OPTICDM LED/7,5W/315lm/SE/AT/1h, IP65 + display L/D
T	FOTOLUMINISČENI PIKTOGRAM DESNO 15X30



Legenda materialov
Armasan beton
Opeka
Toplotna izolacija

±0.00 = 281,80 m n.v.

Investitor: JAVNI STANOVANJSKI SKLAD MOL Zamnikova ulica 3 1000 LJUBLJANA		Naziv objekta: Novogradnja stanovanjsko poslovnega objekta Polje IV Lokacija: k.o. Slape, p.št. 708/3,711/1,712/3,714/5,714/9	
Projektant: "WEGO" Gregor Wolf s.p. Partizanska cesta 16 9250 Gornja Radgona		Vrsta načrta: ELEKTROINŠTALACIJA IN OPREME	
Odg. vodja proj. B. HOJNIK, u.d.i.a.		Risba: KLET-RAZSVETLJAVNA, KABELSKE POLICE	
Odg. projektant D. AMBROŽ, u.d.i.e.		Vrsta projekta: PZI	
Sodelavec		Številka projekta: 01/07-2016/II	
Datum izdelave: FEBRUAR 2018		Št. risbe: 4.2	